




MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SING VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2023/D- 3173

Dated: 21/12/23


HEALTH CERTIFICATE

1. Name of the School H. D. SEHRAWAT PUBLIC SCHOOL
2. School address PLOT NO.71-72, SATYAM VIHAR, NAJAFGARH, ROAD, NEW DELHI- 110043
3. No of shifts 01 (Morning) Timing 08:00 AM TO 1:30 PM
4. No of students:- Boys 365 Girls 285 Total 650
5. No of staff: - Gents 16 Ladies 04 Total 20

Accommodation provide for classroom as under:-

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. Not required
- Drinking water is wholesome/ not wholesome Wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue


Dy. Health Officer
West Zone
Dy Health Officer
West Zone
MCD

TEST REPORT

Description of sample: Drinking Water

Ref No.: Nil

Dated: 22/06/2023

Issued to: The Manager

H.D. Sehrawat Public School,
Plot No. 71-72, Satyam Vihar, Chanchal Park,
Najafgarh Nangloi Road, New Delhi-43

ULR-TC598323000001743P

Date of Report: 26/06/2023

Date of Testing: 23-26/06/2023

Date of Receipt: 22/06/2023

Requirement as per IS-10500:2012

<u>S.No.</u>	<u>Parameters</u>	<u>Test Value</u>	<u>Acceptable Limit Max.</u>	<u>Permissible Limit in absence of alternate source</u>	<u>Method of Test</u>
1	Colour, Hazen Unit	< 5	5	15	IS-3025(P-4):1983
2	Odour	Agreeable	Agreeable	Agreeable	IS-3025(P-5):1983
3	Taste	Agreeable	Agreeable	Agreeable	IS-3025(P-7):1983
4	Turbidity, NTU	0.7	1	5	IS-3025(P-10):1984
5	pH Value	7.2	6.5-8.5	No Relax.	IS-3025(P-11):1983
6	Total Hardness (as CaCO ₃), mg/l	136	200	600	IS-3025(P-21):2009
7	Chloride (as Cl), mg/l	14.2	250	1000	IS-3025(P-32):1988
8	*Residual Free Chlorine, mg/l	Nil	0.2	1.0	IS-3025(P-26):1986
9	Fluoride (as F), mg/l	0.30	1.0	1.5	APHA-23 rd Ed-2017
10	Iron (as Fe), mg/l	0.04	1.0	No Relax.	IS-3025(P-53):1992
11	TDS, mg/l	121.7	500	2000	IS-3025(P-16):1984
<u>Bacteriological Test</u>					
1	Total Coliforms, per 100ml	Absent	Should not be Detectable	-----	IS-1622:1981
2	E-Coli, per 100 ml	Absent	Should not be Detectable	-----	IS-1622:1981


Remark: With respect to the above test, water sample confirms IS-10500-2012 for drinking purpose.

Note: * To be applicable only, when water is chlorinated.

END

Sandesh
Checked by

Subject to Terms & Conditions Overleaf


 Authorised Signatory

RAICON LABS PVT. LTD.

ISO 9001:2015, 14001:2015, 45001:2018, 17025:2017 (NABL) Certified lab.

Regd. Office:

G-18, Aradhana Bhawan, Comm.Complex,
Azadpur, Delhi - 110033

Ph.: +91 11 27672405 | Mob.: +91 7056735652

Email : raicon@raiconlabs.com | Website : www.raiconlabs.com

Laboratory:

Plot No. 140, HSIIDC, Rai Industrial Estate,
Sonepat, Haryana - 131029

Ph.: +91 130 2366144 | Mob.: +91 7206693044